PROVIDENCE WATER

September 17, 2026

Millstone, LLC
250 Centerville Road, Suite E12
Warwick, RI 02886

Re: 0 Western Industrial Drive, Cranston, RI (Plat 36 Lot 1708)
Water Availability

To Whom It May Concern:

In response to your request on September 11, 2026, regarding water availability at the above referenced location, please be advised that Providence Water currently owns and maintains an 8-inch ductile iron water main running along Western Industrial Drive having a static pressure of approximately 65 psi. A new water service installation is required for this location.

Presently, there are sufficient reserves in the Providence Water system for this commercial development. Please be advised that before the water service connection can be made to the Providence Water system, an evaluation of demand must be performed to correctly size the diameter of the commercial service line and water meter size. The fire service line will be sized by your fire suppression consultant. The costs associated with installing the water services and water meter are the responsibility of the applicant.

The applicant must complete and submit Water Service Applications for both Commercial and Fire Services (including Backflow Devices) for review and approval. Please include Site Utility Plans, Plumbing Plans and Fire Suppression Plans when submitting your applications.

Should there be any questions regarding this information, please contact the Providence Water Engineering Department at (401) 521-6300 extension 7102 for assistance.

Respectfully,
PROVIDENCE WATER SUPPLY BOARD

F. St. Sauveur

Federico St. Sauveur
Personnel Assistant, Engineering

CC: File