



RHODE ISLAND
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF WATER RESOURCES
235 Promenade Street, Providence, Rhode Island 02908

December 8, 2023

Mr. Kelly Coates
Amalgamated Financial Equities I LLC
1414 Atwood Avenue
Johnston, RI 02919

RE: WQC/STW File No. 23-072; UIC File No. 002186
Residences At Oaklawn Avenue
Assessor's Plat 17-3, Lot No. 670
Oaklawn Avenue
Cranston, Rhode Island 02920

Dear Mr. Coates:

The Rhode Island Department of Environmental Management Office of Water Resources (RIDEM OWR) has reviewed the above-referenced project for compliance with the RIDEM Groundwater Discharge (GWD)/Underground Injection Control (UIC) Program (Groundwater Discharge Rules: 250-RICR-150-05-4) and the Rhode Island Pollutant Discharge Elimination System Construction General Permit (CGP). The purpose of the project is to construct a new two-story multi-family residential building. Additional site improvements include, but are not necessarily limited to, the following: construction of a new bituminous concrete parking lot, with one access driveway connected to Oaklawn Avenue; landscaping improvements; pedestrian walkways; lighting; and other site amenities. The new stormwater management system includes the following: a subsurface infiltration system (StormTech MC-4500 Chambers) that will receive rooftop-generated stormwater (via roof drains) from the proposed residential building, as well as surface-generated stormwater from a portion of the new parking lot; a proposed bioretention basin, bookended by two (2) sediment forebay areas that receive surface-generated stormwater from the remainder of the new parking lot (either via a paved opening to one forebay or a proposed trench drain that is to be installed across the access driveway); closed drainage with several catch basins and drain manholes, as further described in your application and detailed on site plans consisting of eleven (11) sheets as prepared by Mr. Ryan Stevens, P.E. of Garofalo & Associates, Inc., received by RIDEM OWR on November 15, 2023.

This letter serves as your permit/authorization to discharge for the above-referenced project, provided that you comply with the application materials, the Groundwater Discharge Rules, the CGP and the following conditions:

- 1) You must submit the Notice of Start of Construction Form prior to commencement of any permitted site alterations or construction activity. The Start of Construction Form can be found on the Stormwater Construction Permitting website.
- 2) Prior to construction, you must erect or post a sign resistant to the weather and at least twelve (12) inches wide and eighteen (18) inches long, which identifies the initials "DEM" and the application number(s) assigned to this permit. The sign must be posted in a conspicuous location near the site access and maintained until the project is complete.

- 3) A copy of this permit, any inspection records, and a signed and updated SESC Plan, must be kept at the site at all times until the project is complete. Copies of this permit must be made available for review by any RIDEM or City/Town representative upon request. Electronic versions of required documents that are readily accessible from the construction site area acceptable.
- 4) All fill material shall be clean and free of matter that could cause pollution of the waters of the State.
- 5) The stormwater collection and treatment system approved herein is for the discharge of stormwater only. Any other discharge is prohibited.
- 6) The proposed trench drain (located across the ingress/egress access driveway that intersects with Oaklawn Avenue), which is to be installed in the same location as where R. I. Std. 9.9.0 Construction Access is to be placed, shall either be installed after the Construction Access is removed, or properly protected from damage and sedimentation during construction.
- 7) Any alterations, additions or modifications to the stormwater system from that approved herein, including permanent closure must be reviewed and approved by RIDEM OWR prior to being implemented.
- 8) You must submit the Notice of Termination Form upon completion of the project and final site stabilization. The Notice of Termination Form can be found on the Stormwater Construction Permitting website.
- 9) You are responsible for the long-term inspection, cleaning and maintenance of the stormwater collection and treatment system to ensure proper performance of all components until documentation is provided to indicate that this responsibility has been assumed by another entity. Long-term operation and maintenance is to be as described in the Post-Construction Operation and Maintenance Plan entitled "**Stormwater Management System Operation and Maintenance Plan for: Residences at Oaklawn Ave Assessor's Plat 17-3, Lot 670 Oaklawn Avenue Cranston, Rhode Island**", dated May 1, 2023 (**REV: December 6, 2023**), and prepared by: Garofalo & Associates, Inc..

This permit is not transferable to any person except after written notice to the Director, in the form of a Permit Transfer Form available on the RIDEM Stormwater Construction Permitting website.

This UIC/GWD Registration will expire 4 years from the date of issuance if the stormwater discharge system has not been constructed and installed. Once a registration is expired, a new application must be submitted for any proposed activity subject to the Groundwater Discharge Rules. Your authorization to discharge under the CGP expires at midnight on September 25, 2025. If construction has not been completed by that date, there will be measures in place for you to reauthorize.


RIDEM's Rules and Regulations Governing the Establishment of Various Fees require that RIDES CGP permit holders pay an Annual Fee of \$100.00. An invoice will be sent to the owner on record in May/June of each year if the construction was still active as of December 31st of the previous year. The owner will be responsible for the Annual Fee until the construction activity has been completed, the site has been properly stabilized, and a completed Notice of Termination (NOT) has been received.

You are required to adhere to all above terms and conditions and carry out this project in compliance with the CGP and Groundwater Discharge Rules at all times. Issuance of this permit does not bar RIDEM, nor any of its various Divisions, from initiating any investigation and/or enforcement actions that it may deem necessary for violations this permit or of any and all applicable statutes, regulations and/or permits.

This permit has the full force and effect of a permit issued by the Director. This permit does not relieve your obligation to obtain any other applicable local, state and federal permits prior to commencing construction and does not relieve you of any duties owed to adjacent landowners with respect to changes in drainage. RIDEM assumes no responsibilities for damages resulting from faulty design or construction.

If you have any questions regarding the contents of the permit, you may contact Mr. Gregory R. Swift, Envir. Eng. II at greg.swift@dem.ri.gov or (401) 222-4700, extension 2777708.

Sincerely,

A handwritten signature in blue ink, appearing to read "Gregory R. Swift". The signature is stylized and cursive.

Gregory R. Swift, P.E.
Environmental Engineer II
Stormwater Engineering and 401 Permitting
Office of Water Resources
Rhode Island Department of Environmental Management

cc:

Mr. David Taglianetti, Carpionato Group
Mr. Ryan Stevens, P.E., Garofalo and Associates, Inc.
Mr. Nicholas A. Pisani, P.E., RIDEM
Mr. Chuck Horbert, RIDEM
Mr. Neal Personeus, RIDEM
Mr. Gregory R. Swift, P.E., RIDEM